

3X4X CURB DIMENSION CHANGE NOTICE

WARNING

THE FRESH AIR (FA) BLOWER OUTLET ON HE3XRT AND HE4XRT UNITS HAS MOVED 3" AS OF FEBRUARY 15TH, 2023 AND CURBS PURCHASED BEFORE FEBRUARY 15TH, 2023 WILL NEED AN INTERNAL CURB CROSS MEMBER MOVED 3" SO AS NOT TO OBSTRUCT THE FA OUTLET FOR HE3XRTV, HE3XRTF, HE4XRTV AND HE4XRTF UNITS.

- For HE3XRTV and HE3XRTF units made after February 15th, 2023, verify the FA opening measures 17 ¼" wide, up from 14 ¼". If not, move the 14 ¾" long internal cross member 3", to make the opening 17 ¼" wide to avoid obstructing the FA blower outlet.
- For HE4XRTV and HE4XRTF units made after February 15th, 2023, verify the FA opening measures 37", up from 34". If not, move the 14 ¾" long internal cross member 3", to make the opening 37" wide to avoid obstructing the FA blower outlet.

See updated HE3XRT or HE4XRT dimensional drawings for FA outlet locations as of February 15th, 2023.